



Important Safety Notice

Feb. 12, 2015

Dear Valued Fire Service Professional:

Walter Kidde Portable Equipment Inc. ("Kidde") in conjunction with the U.S. Consumer Product Safety Commission (CPSC) announced a voluntary recall to replace certain Kidde black plastic Zytel® nylon valve disposable fire extinguishers. A copy of the joint press release and the safety notice are enclosed. Kidde has sent copies to our retail customers with instructions to post a copy of the safety notice in stores that sold these extinguishers.

This replacement program was initiated because certain disposable fire extinguishers may not fully discharge when the lever is repeatedly pressed and released. The cause is an out-of-specification valve component.

This recall involves Kidde ABC and BC-rated fire extinguishers manufactured between July 23, 2013 and Oct. 15, 2014 and sold between August 2013 and November 2014. The models are as follows:

FX340SC	RESSP	FC110
FX340GW	Mariner 5 G	FX10
2A10BC	Mariner 5	FX210R
FA10G	FA5B	5BCW
FA110	FX5II	5BC
Mariner 110	FC5	1A 10BC
Mariner 10	FX210	10BC
FX10BC	KFH Twin	1A 10BCW
FX10K	M110 Twin	FH/RESSP
FC10	M5 Twin	XL 5MR
FX210W	FA5B	

Due to our commitment to quality and safety, we have corrected the issue for production going forward, and are working with customers to obtain all recalled units currently in stock.

If you receive inquiries please direct them to contact Kidde at 1-855-283-7991 or [www.Kidde.com](http://www.Kidde.com) to determine whether their extinguishers are affected.

We value our relationship with the state fire marshals and NASFM and appreciate your understanding as we take care of this matter. If you have any questions, please contact Neal Zipser, Kidde's community affairs manager, at 919-304-8264.

We apologize for any inconvenience this may cause and thank you for your cooperation in this matter.

Sincerely,

Chris Rovenstine  
Vice President, Sales and Marketing  
Kidde